



KSCSTE - CENTRE FOR WATER RESOURCES DEVELOPMENT AND MANAGEMENT

ജലവിഭവ വികസന വിനിയോഗ കേന്ദ്രം

(An ISO 9001 : 2015 Certified Organization)

An Institution of Kerala State Council for Science, Technology & Environment, Govt. of Kerala
കേരള ശാസ്ത്ര സാങ്കേതിക പരിസ്ഥിതി കൗൺസിൽ സ്ഥാപനം, കേരള സർക്കാർ



CWRDM WATER QUALITY DIVISION-TESTING LABORATORY

TEST REPORT

No: CWRDM/WQD/WA/8211/2026

ULR -TC1240826000001959F

Customer Name and Address: Little Flower English Medium School Chelavoor	Date of Issue :05-08-2026 Date of receipt of sample :28-07-2026 SRF No :8211/2026 Test Report No :8211/2026/04 Analysis Started :28-07-2026 Analysis Completed :04-08-2026
Information Provided by Customer: Sample Source Sample Type Volume of Sample Supplied Sample Drawn By	Open Well Drinking Water 1L PHI, Kozhikode Municipal Corporation

TEST RESULTS-CHEMICAL ANALYSIS

Sl. No.	Parameters	Test Method	Result	Limit of Quantification (LOQ)	Acceptable limit as per IS 10500:2012
1	pH at 25°C	APHA, 2023 (Part 4500 H+ B)	5.50	1.0	6.50-8.50
2	Colour, Hazen	APHA, 2023 (Part 2120 B)	<1.0	1.0	5.0
3	Turbidity, NTU	APHA, 2023(Part 2130 B)	BDL	0.20	1.0
4	Total Dissolved Solids, mg/l	APHA, 2023 (Part 2540 C)	14.0	10.0	500.0
5	Total Hardness as CaCO ₃ , mg/l	APHA, 2023 (Part 2340 C)	BDL	2.0	200.0
6	Total Alkalinity as CaCO ₃ , mg/l	APHA, 2023 (Part 2320 B)	4.0	2.0	200.0
7	Chloride as Cl ⁻ , mg/l	APHA, 2023(Part 4500 Cl ⁻ B)	4.0	4.0	250.0
8	Sulphate as SO ₄ ²⁻ , mg/l	APHA, 2023 (Part 4500 SO ₄ ²⁻ E)	BDL	1.0	200.0
9	Calcium as Ca, mg/l	APHA, 2023 (Part 3500 Ca B)	BDL	1.0	75.0
10	Magnesium as Mg, mg/l	APHA, 2023 (Part 3500 Mg B)	BDL	1.0	30.0
11	Iron as Fe, mg/l	APHA, 2023 (Part 3500 Fe B)	BDL	0.20	1.0

BDL-Below Detection Limit

Note: -

pH of the water sample is found to be less than the acceptable limit as per IS 10500:2012, Drinking Water Specification. All other tested water quality parameters are found to be within the acceptable limit as per IS10500:2012, Drinking Water Specification.

*****End of the Report*****

For CWRDM, Water Quality Division – Testing Laboratory

Tested by

Swathi.k.s

Authorised & Reviewed by

Ramya

Note: This test report refers only to the particular item(s) submitted for testing. The test results reported in this report are valid at the time of and under the stated condition of measurement. This particular test report cannot be reproduced except in full, without prior permission of Head Water Quality Division of the laboratory. Any discrepancies may be brought to the laboratory within 30 days of the issue of the report.

Kunnamangalam, Kozhikode-673571, Kerala, India | കുന്ദമംഗലം, കോഴിക്കോട്-673571, കേരളം, ഇന്ത്യ

E-mail: ed@cwrmdm.org, registrar@cwrmdm.org | Website: www.cwrmdm.kerala.gov.in

Phone: (91) 495 235 1800, 235 1801

WATER QUALITY DIVISION
CENTRE FOR WATER RESOURCES DEVELOPMENT AND
MANAGEMENT KOZHIKODE-673571

No: CWRDM/WQD/WA/8211/2026N


Customer Name and Address: Little Flower English Medium School Chelavoor	Date of Issue :05-08-2026 Date of receipt of sample :28-07-2026 SRF No :8211/2026 Test Report No :8211/2026/04 Analysis Started :28-07-2026 Analysis Completed :29-07-2026
Information Provided by Customer: Sample Source Sample Type Volume of Sample Supplied Sample Drawn By	Open Well Drinking Water 1L PHI, Kozhikode Municipal Corporation

TEST RESULTS - BACTERIOLOGICAL ANALYSIS

Sl. No.	Parameters	Test Method	Result	Acceptable limit as per IS 10500:2012
1	Total Coliforms, CFU/100ml	APHA, 2023(Part 9222 B)	Absent	Shall not be detectable in any 100ml sample
2	<i>E. coli</i> , CFU/100ml	APHA, 2023(Part 9222 G)	Absent	Shall not be detectable in any 100ml sample

*****End of the Report*****

For CWRDM, Water Quality Division – Testing Laboratory


Tested by


Authorised & Reviewed by
QUALITY MANAGER
CWRDM WATER QUALITY DIVISION
TESTING LABORATORY

Note: This test report refers only to the particular item(s) submitted for testing. The test results reported in this report are valid at the time of and under the stated condition of measurement. This particular test report cannot be reproduced except in full, without prior permission of Head – Water Quality Division of the laboratory. Any discrepancies may be brought to the laboratory within 30 days of the issue of the report.